



FACULTY OF CIVIL ENGINEERING

Department Of Architectural Engineering & Design

UNIVERSITY OF ENGINEERING & TECHNOLOGY, LAHORE.

Phone: +92-42-99029285 URL:- <https://aed.uet.edu.pk/> Email : chairman-aed@uet.edu.pk

Sr Number

007037

Construction Laboratory

Lab Test Report

Client **SADIQ ENTERPRISES THE BEST TILE BOND LAHORE**

Client's Reference No.

NILL

Dated

02/10/2024

Our Reference No.

AED/5120

Dated : **11/11/2024**

TILE BOND

Test Specification:

ASTM-C-109

Received on: **02/10/2024**

TESTED: 05/11/2024

Sr. No.	Brand	Ultimate Load (kN)	Ultimate Stress (psi)	Ultimate Load (kN)	Ultimate Stress (psi)	Weight (Kg)		Days	Water Absorption%
						Wet	Dry		
1	TILE BOND	16.60	923	-	-	-	0.248	3	-
2		18.30	1029	-	-	-	0.246		-
3		18.30	1029	-	-	-	0.248		-
1	SUPER TILE BOND	22.30	1253	-	-	-	0.248	7	-
2		25.70	1444	-	-	-	0.272		-
3		23.40	1315	-	-	-	0.246		-
1	SUPER TILE BOND	34.30	1928	-	-	-	0.249	28	-
2		34.90	1961	-	-	-	0.270		-
3		35.50	1995	-	-	-	0.248		-

Note: The above results pertain to the sample/samples supplied to this laboratory.



Sealed Samples ☒ Unsealed Samples ☒ Marked Samples ☐ Signed Samples




Lab Incharge

Teacher In-Charge

Lecturer

Architectural Engg. & Design Department
University of Engineering & Technology,
Lahore - 54890 Pakistan



Lab Director

Department of Arch. Engg & Design
University of Engineering and Technology,
Lahore. Ph: 042-99029285

9088

Reports may be reviewed or downloaded from Online Report Management System at <https://aed.uet.edu.pk/reports>

To download report, please insert your payment receipt number on above link (MTL:)