



FACULTY OF CIVIL ENGINEERING

Department Of Architectural Engineering & Design

UNIVERSITY OF ENGINEERING & TECHNOLOGY, LAHORE.

Phone: +92-42-99029285 URL:- <https://aed.uet.edu.pk/> Email : chairman-aed@uet.edu.pk

Construction Laboratory

Sr Number

007039

Lab Test Report

Client SADIQ ENTERPRISES THE BEST TILE BOND LAHORE

Client's Reference No. NILL Dated 02/10/2024

Our Reference No. AED/5119 Dated : 11/11/2024 **TILE BOND**

Test Specification: ASTM-C-109 Received on: 02/10/2024 TESTED: 05/11/2024

Sr. No.	Brand	Ultimate Load (kN)	Ultimate Stress (psi)	Ultimate Load (kN)	Ultimate Stress (psi)	Weight (Kg)		Days	Water Absorption%
				-----	-----	Wet	Dry		
1	BEST TILE BOND	25.70	1444	-	-----	-	0.276	3	-----
2		24.60	1383	-	-----	-	0.268		-----
3		26.90	1512	-	-----	-	0.278		-----
1	BEST TILE BOND	30.30	1703	-	-----	-	0.274	7	-----
2		32.60	1832	-	-----	-	0.272		-----
3		36.00	2023	-	-----	-	0.276		-----
1	BEST TILE BOND	56.60	3181	-	-----	-	0.272	28	-----
2		50.90	2861	-	-----	-	0.274		-----
3		42.90	2411	-	-----	-	0.270		-----

Note: The above results pertain to the sample/samples supplied to this laboratory ☐ Sealed Samples ☒ Unsealed Samples ☒ Marked Samples ☐ Signed Samples




Lab Incharge

Teacher In-Charge

Lecturer

Architectural Engg. & Design Department
University of Engineering & Technology,
Lahore - 54890 Pakistan



Lab Director

Department of Arch. Engg & Design
UET Lahore
University of Engineering & Technology,
Lahore. Ph: 042-99029285

9087

Reports may be reviewed or downloaded from Online Report Management System at <https://aed.uet.edu.pk/reports>

To download report, please insert your payment receipt number on above link (MTL: _____)